



- Notes:**
- All levels relate to OD Malin Head and are in meters.
  - Do not scale from this drawing. If in doubt, ask.
  - This drawing should be read in conjunction with all relevant and available documentation.
  - Ordnance Survey Ireland Licence No. EN0002822 © Ordnance Survey Ireland/Government of Ireland.
  - All pipework shall be Polypipe Ridgidrain pipework and fittings, or similar approved.
  - Proposed linear drainage channels to be Aco MultiDrain channels with D400 Brickslot covers to suit the architects proposed finished surface.
  - Proposed road gullies shall be Polypipe Ridgigully with D400 Buffalo 100 ductile iron grating.
  - All runoff from car park areas to be treated by a Class 1 Hydrocarbon separator.
  - All pipes to have a minimum cover of 900mm in non-trafficable areas and 1.2m in trafficable areas.
  - All gully and linear drainage sump outlets to be 150mm dia.
  - All chamber covers to be rated D400 where located in trafficable areas and C250 elsewhere.

**Legend:**

- Existing Culvert
- Existing Open Channel
- Proposed Culvert
- Proposed Surface Water Drain & Manhole
- Proposed Backdrop Manhole
- Proposed Geocellular Surface Water Attenuation
- Proposed Road Gully
- Proposed Linear Drainage Channel & Sump
- Proposed Hydrocarbon Interceptor
- Proposed Planning Boundary
- Proposed Building Outline
- Extent of Podium

Rev	Date	By	Chkd	Appd
P07	21/03/22	ROD	RM	JMAC
Issued for Information (Status S2)				
P06	02/02/22	ROD	RM	JMAC
Issued for Information (Status S2)				
P05	17/12/21	ROD	RM	JMAC
Issued for Information (Status S2)				
P04	01/12/21	ROD	RM	JMAC
Issued for Information (Status S2)				
P03	19/11/21	RM	RM	JMAC
Issued for Information (Status S2)				
P02	10/09/21	ROD	RM	JMAC
Issued for Information (Status S2)				
P01	01/09/21	ROD	RM	JMAC
Issued for Information (Status S2)				

**ARUP**  
 One Albert Quay  
 Cork, Ireland  
 Tel +353 (0)21 427 7670 Fax +353 (0)21 427 2345  
 www.arup.com

Client  
**Tiznow Property Company Limited (Comer Group Ireland)**

Project Title  
**Former Cork Warehouse Site**

Drawing Title  
**Proposed Surface Water Layout**

Scale at A1: 1:250  
 Role: Site Infrastructure  
 Suitability: S2 - Suitable for Information  
 Anup Job No: **267365-00** Rev: **P07**  
 Name: **267365-ARUP-ZZ-ZZ-DR-C-2100**